WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93176
Permit No. 60636
Basin 105

NOTICE OF INTENT NO. 52445

1. OWNER Town of Minden
MAILING ADDRESS PO Box 205
Minden, NV 89423

ADDRESS AT WELL LOCATION old well #2

2. LOCATION NE 1/4 NW 1/4 Sec. 32 T 13N N/S R 20E E Douglas County
PERMIT NO. 60636 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDONMENT				
Pumped 14cy of neat				
cement. (30,268 lbs of				
cement and 1,610				
gallions of water). The				
calculated volumne was 8				
cy of cement and we used				
14 cy.				
We tried to reverse the				
sand from the well, but				
could only get down to				
277 ft. Old log shows				
the well was 300 ft.				
When the reverse pipe				
hit the bottom of the				
well it hit hard and the				
water would stop,				
indicating the bottom of				
the well is flat.				
Therefore, we abandoned				
the well from 277 ft. to				
the surface.		0	277	277

Date started 4/16/04, 19__
Date completed 4/16/04, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 277
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 16.55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154/2177

Signed (By driller performing actual drilling on-site or contractor)

Date 4/29/04