

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT ONLY  
 Log No. **93252**  
 Permit No. **63313**  
 Basin **215**

NOTICE OF INTENT NO. **26532**

1. OWNER Sandia Sand and Gravel ADDRESS AT WELL LOCATION 10 Miles East of Area ext I-15  
 MAILING ADDRESS 1973 N. Neil's Blvd #338  
Las Vegas, Nv. 89115  
 2. LOCATION NE 1/4 SE 1/4 Sec. 29 T 20 N R 64 E Clark County  
 PERMIT NO. 63313 Issued by Water Resources Parcel No. 142-00-003-004 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		630	665	35
Sand, silt, gravel		665	800	135
Mudstone		800	840	40
Sandstone		840	1040	200

Well was 630' and only producing 20 GPM.  
 Used symmetric method to pull 430' of 6" perforated casing down to 1040'.  
 Overlapped casing 20' at reduction point.

DCNR/DWR  
 RECEIVED  
 MAY 24 2004  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 1040 Feet Depth Cased 1040 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 630 Feet 1040 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.02	.250	610	1040

Perforations:  
 Type perforation factory milled  
 Size perforation 1/8 x 2 1/2  
 From 610 feet to 1040 feet  
 \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 247 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started May 13 2004  
 Date completed May 14 2004

7. WELL TEST DATA

	TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
May 17	70	310'	6 hrs

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Webber Drilling Contractor  
 Address 2475 W. 3935 St. Contractor  
WVC, Lt. 84119  
 Nevada contractor's license number issued by the State Contractor's Board 0025887  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238  
 Signed Bryan Arizabne  
 By driller performing actual drilling on site or contractor  
 Date May 22, 2004