WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93254
Permit No. 69637
Basin 212

NOTICE OF INTENT NO. 25266

1. OWNER Las Vegas Valley Water Dist.
MAILING ADDRESS 1001 S. Valley View Blvd.
Las Vegas NV. 89153

ADDRESS AT WELL LOCATION Echo Rd. & Kyle Canyon

2. LOCATION SW ¼ NE ¼ Sec. 26 T 19 N/S R 56 E Clark County
PERMIT NO. 69637 T (Issued by Water Resources) | 12926801002 (Parcel No.) | Kyle Canyon (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other ✓

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravels, Cobbles, silts.		0	212	212
Lime Stone		212	320	108

* Borehole was abandoned with 6 yards of Neat cement. Trimie pipe was placed at Bottom of Borehole and Cement was pumped from Bottom to surface.

DCNR/DWR RECEIVED MAY 2 2004 LAS VEGAS OFFICE

RECEIVED 04 MAY 25 AM 11:02 STATE ENGINEERS OFFICE

Date started 6-3-03, 19
Date completed 6-20-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
R.C.	200 +	u.k.	

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased None Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From (Feet)	To (Feet)
	6¼	0	320

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 320'. Abandoned.
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 10° C Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beylik Drilling Inc. (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2145
Signed [signature] Beylik Drilling (By driller performing actual drilling on site or contractor)
Date 5-21-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627