WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93256
Permit No.
Basin 162

NOTICE OF INTENT NO. 25693

1. OWNER CLIFFORD WHISENHUNT
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4401 E. ASHLEY

2. LOCATION NE ¼ NW ¼ Sec. 29 T. 21 N/S R. 54 E. NYE County
PERMIT NO. (Issued by Water Resources) 45-322-04 (Parcel No.) GLEEN SADDLE RCH. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN. CLAY		0	5	5
PEA-GRAVEL		5	7	2
BRN. CLAY		7	10	3
BRN. SAND STONE		10	13	3
BRN. CLAY		13	20	7
BRN. LIME STONE		20	23	3
BRN CLAY		23	30	7
BRN SAND STONE		30	34	4
BRN CLAY		34	51	17
BRN LIME STONE		51	54	3
BRN CLAY		54	60	6
LT BRN CLAY	X	60	73	13
BRN CLAY	X	73	115	42
BRN LIME STONE	X	115	117	2
LT. BRN CLAY	X	117	127	10
BRN CLAY	X	127	140	13
BRN LIME STONE	X	140	146	6
BRN CLAY	X	146	160	14

DCNR/DWR
RECEIVED
MAY 21 2004
LAS VEGAS OFFICE

Date started 4-24, 2004
Date completed 5-19, 2004

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	10	½ HOUR

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		SCD 40	0	160

Perforations:
Type perforation SAW CUT
Size perforation 1/8 x 6"
From 100' feet to 150' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 160' feet

9. WATER LEVEL
Static water level 70' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lahys Water Well Service (Contractor)
Address P.O. Box 3392 Pahrump NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed (By driller performing actual drilling on site or contractor)
Date 5-19-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627