WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93323
Permit No.
Basin 70

NOTICE OF INTENT NO. 52446

1. OWNER Randy Badger
MAILING ADDRESS 4190 W. Cessna
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 4190 W. Cessna

2. LOCATION NE 1/4 NE 1/4 Sec. 23 T 35N N/S R 37E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 14-084-05 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy clay		100	103	
sandy gravel	x	103	116	13
sandy clay		116	118	2
sand	x	118	126	8
clay		126	128	2
sand w/s gravel	x	128	145	17
sandy clay		145	148	3
sand/gravel	x	148	154	6

RECEIVED
04 MAY 18 AM 10: 27
STATE ENGINEERS OFFICE

Date started 5/14/04 , 19__
Date completed 5/14/04 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20 +		

8. WELL CONSTRUCTION
Depth Drilled 154 Feet Depth Cased 154 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	100 Feet	154 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5-9/16		.188	92	154

Perforations:
Type perforation mill slot
Size perforation .100
From 92 feet to 154 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal _____
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2235

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 5/15/04