

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 93463  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 25968

1. OWNER Nancy & Ernie Hughes ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4291 W. Joann 4291 W. Joann  
Pahrump, NV 89060

2. LOCATION SE 1/4 NE 1/4 Sec. 23 T 20S N/S R 52E E Nye County  
 PERMIT NO. 41-443-10 Golden Spring Ranch  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown loam</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>grey loam</u>		<u>3</u>	<u>16</u>	<u>13</u>
<u>brown loam</u>		<u>16</u>	<u>21</u>	<u>5</u>
<u>See next line</u>	<u>x</u>	<u>21</u>	<u>78</u>	<u>57</u>
<u>brown loam with caleche strings</u>				
<u>grey loam</u>	<u>x</u>	<u>78</u>	<u>122</u>	<u>44</u>
<u>brown loam</u>	<u>x</u>	<u>122</u>	<u>133</u>	<u>11</u>
<u>See next line</u>	<u>x</u>	<u>133</u>	<u>152</u>	<u>19</u>
<u>brown loam with caleche strings</u>				
<u>grey loam</u>	<u>x</u>	<u>152</u>	<u>160</u>	<u>8</u>

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160+1 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
11 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation sawcut  
 Size perforation .188  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 62 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor  
 Address 5801 S. Homestead Contractor  
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed \_\_\_\_\_ By driller performing actual drilling on-site or contractor  
 Date 6-27-04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR  
 RECEIVED  
 JUL 07 2004  
 LAS VEGAS OFFICE