

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93528
Permit No. 212
Basin 212

NOTICE OF INTENT NO. 26301

1. OWNER SNWA ADDRESS AT WELL LOCATION LAS VEGAS SPRINGS RESERVE

MAILING ADDRESS 1700 E. FLAMINGO LAS VEGAS, NV 89119 Clark County

2. LOCATION S 20 1/4 NE 1/4 Sec. 31 T. 20 N/S R. 61 E. Parcel No. 139-31-602-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial Irrigation Test Cable
 Monitor Stock Air Rotary RVC
 Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TYPE II		0.0	2.5	2.5
Alchic		2.5	8.0	5.5
CEMENTED SAND & GRAVEL		8.0	10.0	2.0
SANDY CLAY w/silt		10.0	30.0	20.0
CLAY w/silt		30.0	45.0	15.0
SILTY SAND w/silt		45.0	70.0	25.0
SILTY CLAY w/silt & gravel		70.0	110.0	40.0

8. WELL CONSTRUCTION
 Depth Drilled 110.0 Feet Depth Cased 110.0 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 1/2 Inches To 00 Feet
 From 00 Feet To 140.0 Feet
 From 00 Feet To 00 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>5/8 40 P/L</u>	<u>140.0</u>	<u>0.0</u>

Perforations: Machine slotted sch 80
 Type perforation 8.0
 Size perforation 140.0 feet to 120.0 feet
 From 140.0 feet to 120.0 feet
 From 120.0 feet to 115.0 feet
 From 115.0 feet to 110.0 feet

Surface Seal: Yes No Seal Type: Neat Cement Cement GROUT Concrete GROUT
 Depth of Seal 3.0
 Placement Method: Pumped Poured
 Gravel Packed: Yes No

9. WATER LEVEL
 Static water level 24.28 feet below land surface
 Artesian flow 0 G.P.M. P.S.I.
 Water temperature 0 °F Quality 0

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ERACLE DRIVING SERVICES
 Contractor

Address 7150 PINE Contractor
LAS VEGAS, NV 89119

Nevada contractor's license number 51266
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202

Signed [Signature]
 by driller performing actual drilling on site or contractor
 Date 6/24/04

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

Date started	Date completed	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>5/13</u>	<u>2004</u>			
<u>5/17</u>	<u>2004</u>			