WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 93539
Permit No.
Basin 222

NOTICE OF INTENT NO. 26255

1. OWNER Alan Glon
MAILING ADDRESS P.O. Box 267
Mesquite, NV

ADDRESS AT WELL LOCATION 950 West Mesquite Blvd.
Mesquite, NV

2. LOCATION SW ¼ NE ¼ Sec. 18 T. 13 N/S R. 71 E. Clark County
PERMIT NO. ~~001-18-701-002~~ Issued by Water Resources | 001-18-701-002 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other 115A

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Type II fill | | 0.0 | 2.0 | 2.0 |
| Sand/S.H. | | 2.0 | 51.0 | 49.0 |

Date started 2/25, 2004
Date completed 2/25, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 51' Feet Depth Cased 51' Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 11 1/2 Inches | | 0.0 Feet | 51.0 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.250 | | Sch 40 PVC | 0.0 | 41.0 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine slotted
Size perforation .020
From 51.0 feet to 41.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 51' feet to 32.0' feet

9. WATER LEVEL
Static water level 47.0' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid St. (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
(Signed) [signature] By driller performing actual drilling on site or contractor
Date 3-11-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627