

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93639  
 Permit No. \_\_\_\_\_  
 Basin 30A

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52442

1. OWNER Ron Mestre ADDRESS AT WELL LOCATION Kings River Valley  
 MAILING ADDRESS 20 Pacetti Circle  
Reno, NV 89511

2. LOCATION NW 1/4 NW 1/4 Sec. 6 T 44N N/S R 34E E Humboldt County  
 PERMIT NO. converted to domestic Issued by Water Resources R-961/R-461A/17674 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>This was an irrigation well—</u>				
<u>Ran the holt perforator down to 100 ft. Set 8-5/8 casing to 300 ft. Set gravel to 80 ft. and pumped neat cement between the 16 inch and 8 inch casing to the surface</u>				
<u>Reconditioned</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)  
 From 16 Inches 0 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8-5/8</u>		<u>.188</u>	<u>+2</u>	<u>100</u>
<u>8-5/8</u>		<u>.250</u>	<u>260</u>	<u>280</u>

Perforations:  
 Type perforation mill slot  
 Size perforation .090

From 100 feet to 260 feet  
 From 280 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 80  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 80 feet to 300 feet

9. WATER LEVEL  
 Static water level 85 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed Jewell Tompkins  
 By driller performing actual drilling on-site or contractor  
 Date 4/23/04

Date started 4/3/04, 19\_\_\_\_  
 Date completed 4/3/04, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

APR 26 PM 1:41  
 STATE ENGINEERS OFFICE