WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93642
Permit No.
Basin 71

Revision to correct static

NOTICE OF INTENT NO. 51951

1. OWNER Rawhide Estates LLC
MAILING ADDRESS 9200 S. Beechcraft Blvd
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 10765 Reins Way

2. LOCATION SE 1/4 SE 1/4 Sec. 31 T 35N N/S R 38E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 10-627-08 Parcel No. | Rawhide Estates - Lot 28 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand/gravel/cobbles		0	50	
boulders		50	53	3
sandy gravel/cobbles		53	80	27
sand, gravel, 20% clay		80	82	2
cobbles		82	85	3
sandy gravel		85	90	5
cobbles/gravel		90	144	54
coarse sand		144	159	15
cobbles		159	191	32
coarse sand		191	195	4
cobbles		195	203	8
sand	x	203	212	9
cobbles & gravel	x	212	265	53
boulders & gravely clay		265	285	20
sandy gravel	x	285	297	12
cobbles & gravel	x	297	370	73

STATE OF NEVADA
OCT 4 A 10:48

Date started 4/23/04 , 19__
Date completed 4/25/04 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		3.5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 370 Feet Depth Cased 365 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	370 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	285

Perforations:
Type perforation mill slot
Size perforation .090
From 285 feet to 365 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 56
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 56 feet to 370 feet

9. WATER LEVEL
Static water level 205 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2235

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 4/30/04