COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 936056
Permit No.
Basin 101

NOTICE OF INTENT NO. 54574

1. OWNER Frank Woolsey
MAILING ADDRESS Lot #167 Pelican Road
Fallon, NV 8906

ADDRESS AT WELL LOCATION Frank Woolsey
Lot #167 Pelican Road 4473 Pelican Road
Fallon, NV 89406

2. LOCATION sw ¼ se ¼ Sec 21 T 19n N R 28e E Churchill County
PERMIT NO. (Issued by Water Resources) NA (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Gray Clay		8	23	15
Brown Gravel		23	38	15
Brown Clay		38	42	4
Black Clay		42	45	5
Black Sand/Gravel		45	56	11
Brown Clay		56	60	4
Brown Gravel	XX	60	68	8

RECEIVED 04 AUG -5 PM 12:14 STATE ENGINEERS OFFICE

Date started 04/05, 20 04
Date completed 0405, 20 04

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 68 Feet Depth Cased 68 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	68 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	68

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 65 feet to 68 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 68 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 07/15/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com