COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93665
Permit No.
Basin 101

NOTICE OF INTENT NO. 54575

1. OWNER Frank Woolsey
MAILING ADDRESS Lot #148 Meadowlark
Fallon, NV 8906

ADDRESS AT WELL LOCATION Frank Woolsey
Lot#148 Meadowlark 1407 meadowlark
Fallon, NV 89406

2. LOCATION NW ¼ NE ¼ Sec 21 T 19n N R 28e E Churchill County

PERMIT NO. (Issued by Water Resources) NA (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Gray Clay		10	23	13
Brown Gravel		23	38	15
Gray Clay		38	46	8
Black Sand		46	50	4
Black /Gray Clay		50	52	2
Black Sand		52	62	10
Brown Gravel	XX	62	70	8

RECEIVED 04 AUG -5 PM 12:14 STATE ENGINEERS OFFICE

Date started 04/06/ , 20 04
Date completed 04/06 , 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	70 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	70

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 65 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 70 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 07/15/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com