

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93691
 Permit No. _____
 Basin 88

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **52181**

1. OWNER Truppi Const. ADDRESS AT WELL LOCATION 19650 Anne Lane Pleasant Valley
 MAILING ADDRESS 3550 Barron Way Ste. 7A
Reno, NV 89511

2. LOCATION NW 1/4 SE 1/4 Sec. 4 T 17N N/S R 20E E Washoe County
 PERMIT NO. _____ Parcel No. 017-320-24 Submission Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replaca Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown coarse and fine sand	x	0	115	115
Brown coarse sand with gravel	x	115	195	80
Brown clay mixed sand and gravel	x	195	215	20
Sand and gravel some clay	x	215	256	41

Washoe County Well Permit # WL 040129

RECEIVED
 04 JUL -1 AM 11:25
 STATE ENGINEERS OFFICE

Date started 6/16/2004 19
 Date completed 6/22/2004 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>70</u>		<u>3</u>

8. WELL CONSTRUCTION
 Depth Drilled 256 Feet Depth Cased 256 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 5/8</u>	<u>0</u>	<u>256</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Fl. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>256</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3

From	feet to	feet
	<u>156</u>	<u>196</u>
	<u>236</u>	<u>256</u>

Surface Seal: Yes No
 Depth of Seal 103
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 103 feet to 256 feet

Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
 Contractor
 Address 1600 Mt. Rose Hwy
 Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 6/28/2004