

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 93732  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. 49762

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER KURT JOHNSON DEVELOPMENT ADDRESS AT WELL LOCATION 1969 LACEY LANE  
 MAILING ADDRESS 248 MARK STREET GARDNERVILLE, NV 89410  
GARDNERVILLE, NV 89410

2. LOCATION SE 1/4 SE 1/4 Sec 24 T 12 N R 20 E DOUGLAS County

PERMIT NO. 1220-24-701-042

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	5	5
BROWN CLAY		5	15	10
COURSE GRAVELS		15	78	63
BROWN CLAY	(DRY)	78	162	84
BROWN GUMMY CLAY		162	192	30
SMALL SILTY SANDS		192	213	21
SMSALL OBSIDIAN SANDS AND GRAVELS	XX	213	265	52

RECEIVED  
 04 AUG -5 AM 11:51  
 STATE ENGINEERS OFFICE

Date started 7/10, 20 04  
 Date completed 7/11, 20 04

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<u>30</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Draw Down (Feet Below Static)			
<u>40</u>			
Time (Hours)			
<u>3 HRS</u>			

8. WELL CONSTRUCTION

Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 5/8</u> Inches	<u>0</u> Feet <u>265</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>265</u>

Perforations:

Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32

From 245 feet to 265 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 265 feet

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address 20 KIT KAY DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed Rock Crane  
 By driller performing actual drilling on site or contractor  
 Date 7/10/04