WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93743
Permit No.
Basin 105

NOTICE OF INTENT NO. 53485

1. OWNER Greg Lynn Construction
MAILING ADDRESS 1222 Bobwire LN
Gardnerville NV 89460
ADDRESS AT WELL LOCATION 2590 Bowers LN
Gardnerville NV 89410

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 1221-09-001-008 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil, Clay Brown		0	12	12
Rock, Grey		12	16	4
Clay Grey		16	34	18
Rocks, small Granit		34	68	34
Clay, Grey		68	135	67
Sand + small Gravel		135	172	37
Clay Brown		172	196	24
Shale, dark Brown		196	216	20
Granit Rock		216	221	5
Shale, dark Brown		221	286	65
Clay Grey		286	318	32
Gravel + Rock		318	336	18

Date started 6-30-04, 20
Date completed 7-19-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	20	40	1.5

8. WELL CONSTRUCTION
Depth Drilled 336 Feet Depth Cased 336 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	56 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	0.188	+1	335

Perforations:
Type perforation Factory
Size perforation 3/32" x 2.5"
From 145 feet to 165 feet
From 315 feet to 335 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 56'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 56 feet to 335 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ground Pounders Well drilling (Contractor)
Address 1374 HW 395 S. Gardnerville (Contractor)
NV 89410
Nevada contractor's license number issued by the State Contractor's Board 0057531
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed George E. Steele (By driller performing actual drilling on site or contractor)
Date 25 July 04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

04 AUG 16 AM 11:01 STATE ENGINEERS OFFICE
DONE/DWR RECEIVED