WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93744
Permit No.
Basin 105

NOTICE OF INTENT NO. 53488

1. OWNER Sunshine Construction
MAILING ADDRESS PO Box 1538
Minden NV 89423

ADDRESS AT WELL LOCATION 1056 Country LN
Gardnerville NV 89460

2. LOCATION S/W ¼ N/W ¼ Sec. 20 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 1220-20-001-022 (Parcel No.) Country Lane (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + Large Gravel		0	20	20
Sand, River Gravel + Rocks	✓	20	142	122
Granit w/Some Black, Hard Stringers	✓	142	195	53

RECEIVED 04 AUG 16 AM 11:01 STATE ENGINEERS OFFICE

DONR JWR RECEIVED AUG 2 LAS VEGAS

Date started 7-20, 20
Date completed 7-26, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	40	60	1

8. WELL CONSTRUCTION
Depth Drilled 195 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	195 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	338 for 20'	0.188	+1	195

Perforations:
Type perforation Factory
Size perforation 1/8" x 3"
From feet to feet
From 95 feet to 115 feet
From 135 feet to 155 feet
From 175 feet to 195 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 54 ft
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 54 feet to 195 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ground Pounders Well Drilling (Contractor)
Address 1374 HW 395 S. Gardnerville (Contractor)
NV 89410
Nevada contractor's license number issued by the State Contractor's Board 0057531
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed George E. Steele (By driller performing actual drilling on site of contractor)
Date 30 July 04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (0)-627