COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93825
Permit No.
Basin 212

NOTICE OF INTENT NO. 26617

1. OWNER PECOS SERENE INVESTMENTS LLC
MAILING ADDRESS 701 N GREEN VALLEY PKWY #220
HENDERSON, NV 89074-6178

ADDRESS AT WELL LOCATION 3333 E SERENE AVE
HENDERSON, NV

2. LOCATION NE ¼ SE ¼ Sec 24 T 22 S R 61 E CLARK County

PERMIT NO. R-1248 (Issued by Water Resources) | 177-24-702-005 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
As per wavier #R-1248				
Plug 1-248' domestic well				
well blocked at40'. drilled				
down to 80' and hit steel				
drop pipe.Used milling bit				
and exited the casing and				
encountered native soil.				
Owner informed us that				
they attemped to remove				
the pump and dropped to				
bottom. Which we found				
evidence of wire,steel pipe				
and well casing. well				
making approx. 50 gal. a				
minute. well was fully				
perforated. resitance of				
removal of drill pipe,				
withdraw bit up to 146'.				
casing collapsed as we				
were drilling. Unscrew				
drill pipe. one joint and				
drill bit left at the 146'.				
Cement hole at 148'.				
Freefall 7 yards of W171				
cement slurry into well.				

DCNR/DWR
RECEIVED
AUG 1 1 2004
LAS VEGAS OFFICE

Date started 7/26/04, 20
Date completed 7/26/04, 20

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL

Static water level ____ feet below land surface
Artesian flow ____ G.P.M ____ P.S.I
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B Allen III
By driller performing actual drilling on site or contractor
Date 8/6/04

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com