WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93900
Permit No.
Basin 101

NOTICE OF INTENT NO. 52731

1. OWNER STEVE BEYER
MAILING ADDRESS 1370 SHECKLER CUTOFF
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1370 SHECKLER CUTOFF

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
Parcel No. 005-654-04
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	5	4
BROWN SAND/CLAY		5	20	15
BROWN CLAY		20	24	4
BROWN SAND		24	34	10
GRAY CLAY		34	40	6
GRAY SANDS		40	60	20
GRAY SANDS/CLAY		60	71	11
GRAY CLAY		71	76	5
BROWN SANDS	X	76	86	10

RECEIVED
04 JUN 10 AM 11:09
STATE ENGINEERS OFFICE

Date started 5/14/2004, 19__
Date completed 5/14/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION
Depth Drilled 86 Feet Depth Cased 86 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	86	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	86

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 79 feet to 84 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 18' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 6/7/2004

USE ADDITIONAL SHEETS IF NECESSARY