

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 93910
Permit No. _____
Basin 152

NOTICE OF INTENT NO. 53407

1. OWNER Linda Coggburn ADDRESS AT WELL LOCATION 7155 ANNETTA SILVER SPRINGS, NV
MAILING ADDRESS _____
2. LOCATION NW 1/4 SW 1/4 Sec. 13 T. 17 N/S R. 24 E. LYON County
PERMIT NO. _____ Issued by Water Resources 107-22103 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other MWD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT-ROCK		0	35	35
LOOSE COBBLES		35	55	20
FRACTURED ROCK		55	86	31
BLONDE CLAY-FR ROCK		86	94	8
FRAC ROCK		94	135	41
BLONDE CLAY-FR ROCK		135	173	38
FRAC ROCK		173	214	41
BROWN CLAY		214	246	32
BR CLAY-GRAVEL		246	284	38
FRAC ROCK		284	314	30

8. WELL CONSTRUCTION
Depth Drilled 314 Feet Depth Cased 314 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 100 Feet
8 3/4 Inches 100 Feet 314 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>314</u>

Perforations:
Type perforation Factory milled
Size perforation 3/32" x 3"
From _____ feet to _____ feet
From 274 feet to 314 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 52 ft Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 52 feet to 314 feet

9. WATER LEVEL
Static water level 210 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality TINTED YELLOW

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC.
Address P.O. Box 1255 Carson City, NV 89702
Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dalton
By driller performing actual drilling on site or contractor
Date _____

Date started 19 APR, 2004
Date completed 22 APR, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10-12</u>		<u>2.5</u>

RECEIVED
04 JUN 10 PM 3:39
STATE ENGINEERS OFFICE