WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93916
Permit No.
Basin 1D

NOTICE OF INTENT NO. 54387

1. OWNER NORMAN FREY-RAMBLIN RIVER RANCH
MAILING ADDRESS 3975 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 3975 RENO HWY

2. LOCATION SW 1/4 NW 1/4 Sec. 27 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. 66558 (Issued by Water Resources)
008-411-95 (Parcel No.)
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN CLAY/SANDS		1	20	19
BROWN SAND		20	40	20
BROWN CLAY		40	41	1
GRAY SAND		41	80	39
GRAY CLAY		80	83	3
BROWN SANDS		83	100	17
GRAY SAND & CLAY		100	120	20
GRAY SAND		120	155	35
GRAY CLAY		155	158	3
BROWN SANDS		158	184	26
BROWN CLAY		184	188	4
BROWN SAND & SILT		188	200	12
BROWN CLAY		200	203	3
BROWN SANDS		203	250	47
BROWN CLAY		250	260	10

RECEIVED 04 JUN -8 AM 10:54 STATE ENGINEERS OFFICE

Date started 1/15/19~~04~~ 20, 19__
Date completed 5/4/19~~04~~ 20, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
575	42'	48 hrs

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	100	Feet
20	Inches	100	Feet	260	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12		.188	+2	260
20			0	100

Perforations:
Type perforation JOHNSON SCREEN
Size perforation
From 205 feet to 255 feet
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6/6/2004

USE ADDITIONAL SHEETS IF NECESSARY