WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93946
Permit No.
Basin 89

NOTICE OF INTENT NO. 51697

1. OWNER Myles Martin
MAILING ADDRESS 505 Ora Loma
Washoe, NV 51697

ADDRESS AT WELL LOCATION 505 Ora Loma

2. LOCATION NE 1/4 SE 1/4 Sec. 23 T 17N N/S R 19E E Washoe County
PERMIT NO. R-468 (Issued by Water Resources) 050-235-08 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown coarse sand		0	15	15
Gray fine sand some coarse	x	15	75	60
Tan and brown sand	x	75	95	20
Gray fine sand	x	95	175	80
Gray coarse sand some fine	x	175	235	60
Fine sand layers clay		235	257	22

Washoe County Well Permit # WL 040151

RECEIVED 04 JUL 28 AM 10:53 STATE ENGINEERS OFFICE

Date started 6/29/2004, 19__
Date completed 6/30/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		3

8. WELL CONSTRUCTION
Depth Drilled 257 Feet Depth Cased 257 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	257	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	257

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 197 feet to 237 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 257 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 7/1/2004

USE ADDITIONAL SHEETS IF NECESSARY