3 Wells

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94870
Permit No.
Basin 212

NOTICE OF INTENT NO. 25993

1. OWNER Gary Kern
MAILING ADDRESS 3130 Hansen Way
Palo Alto, CA

ADDRESS AT WELL LOCATION 6883 Spencer St.
Las Vegas, NV

2. LOCATION SW ¼ NW ¼ Sec. 2 T. 22 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) | 177-02-212-006 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Aspalt		0	.5	.5
Type 2		.5	2	1.5
Silty Sand w/clay		2	10	8
Caliche		10	12	2
Silty Sand		12	18	6
Silty Clay		18	25	7
Clay w/gravel		25	30	5
Silty Sand	X	30	34	4
Silty Sand w/gravel		34	41	7
Silty Sand w/clay		41	45	4

DCNR/DWR
RECEIVED
JAN 04 2005
LAS VEGAS OFFICE

Date started 09-18, 2004
Date complated 09-20, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.25		Sch 40 PVC	0	45

Perforations:
Type perforation Machine Slotted
Size perforation .020
From 30 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 30
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 45 feet to 32 feet

9. WATER LEVEL
Static water level 33 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services LLC (Contractor)
Address 7150 Placid (Contractor)
Las Vegas, NV
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed Victor [illegible] (By driller performing actual drilling on site or contractor)
Date 11/05/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627