COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94965
Permit No.
Basin 105

NOTICE OF INTENT NO. 53529

1. OWNER GARY LIST VERUS CONSTRUCTION
MAILING ADDRESS 1615 HWY 395 NORTH
MINDEN, NV 89403

ADDRESS AT WELL LOCATION 1699 SOUTH BENTON RD
GARDNERVILLE, NV 89410

2. LOCATION NE ¼ NE ¼ Sec 26 T 13 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1320-26-001-033 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| OVER BURDEN | | 0 | 3 | 3 |
| HARD PAN CLAY | | 3 | 9 | 6 |
| COURSE DG GRAVELS | | 9 | 45 | 36 |
| BROWN CLAY | | 45 | 110 | 65 |
| SMALL OBSIDIAN GRAVELS | | 110 | 162 | 525 |
| BROWN GUMMY CLAY | | 162 | 203 | 41 |
| FRACTURED GRAVELS SMALL SILTY SAND LAYERS | XXX | 203 | 240 | 37 |

RECEIVED 04 DEC 14 AM 10:52 STATE ENGINEERS OFFICE

Date started 11/4, 20 04
Date completed 11/6, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | 65 | 3 HRS |

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 3/4 | Inches | 0 Feet | 240 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | +2 | 20 |
| sdr 21 6 5/8 | 4.06 | .216 | 20 | 240 |

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 240 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M 25 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89410
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 12/10/04


Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429