COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95149
Permit No.
Basin 103 49750
NOTICE OF INTENT NO. ~~49749~~

1. OWNER CORNERSTONE CONSTRUCTION
MAILING ADDRESS 1273 FIREURO WY
CARSON CITY, NV 89701
ADDRESS AT WELL LOCATION 7205 IRON MTN BLVD
DAYTON NV, 89443

2. LOCATION SE ¼ SE ¼ Sec 7 T 17 N R 23 E LYON County
PERMIT NO. (Issued by Water Resources) 15-324-14 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY AND COBBLES		0	3	3
VOLCANIC GRAVELS		3	87	85
BROWN CLAY		87	96	9
COBBLES AND SANDS		96	128	32
BROWN CLAY		128	160	32
VOLCANIC FRACTURE	XXX	160	200	40
LOST CIRCULATION AT 160'				

RECEIVED 04 JUN 25 AM 10:45 STATE ENGINEERS OFFICE

Date started 5/16, 20 04
Date completed 5/17, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	15	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	5/8	.188	0	200

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 200 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89701
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 6/14/04

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9428