

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25871

1. OWNER Dave Barnett ADDRESS AT WELL LOCATION # 1 Pum
 MAILING ADDRESS Po Box 763 R.D. Caliente Nev. 89008
Caliente New 89008
 2. LOCATION SE 1/4 SW 1/4 Sec. 14 T. 3 N. R. 67 E. 10 Lincoln County
 PERMIT NO. _____ Parcel No. 013-170-79 Subdivision Name McDon Valley Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	40	40
Sandy Clay Gravel		40	45	5
Sandy Gravel		45	80	35
Sandy Clay Gravel Gravel		80	90	10
Clay		90	118	28
		118	133	15

8. WELL CONSTRUCTION
 Depth Drilled 133 Feet Depth Cased 133 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches 0 Feet 133 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>0</u>	<u>133</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 1/8 inch
 From 60 feet to 123 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54 Feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 133 feet

**UNINH/DWR
 RECEIVED
 FEB 22 2005
 LAS VEGAS OFFICE**

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow non G.P.M. 0 P.S.I.
 Water temperature 41 °F Quality Good

Date started 12-16 2004
 Date completed 12-23 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>105</u>	<u>4 Feet</u>	<u>4 Hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge. De Lou Wensor
 Name Ronald K Wensor Contractor
 Address Po Box 119 Newcastle Contractor
UT 89756
 Nevada contractor's license number issued by the State Contractor's Board 35005
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 782,703
 Signed Ronald K Wensor
 By driller performing actual drilling on site or contractor
 Date 12-22-04