

*E/m Via Catalina*

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 95198  
 Permit No. \_\_\_\_\_  
 Basin 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51992

1. OWNER Don Evans ADDRESS AT WELL LOCATION 9851 Via Catalina  
 MAILING ADDRESS \_\_\_\_\_ Silver Springs, NV  
 2. LOCATION SE 1/4 SE 1/4 Sec. 23 T. 17 N/S R. 24 E Myon County  
 PERMIT NO. 17-545-08 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand &amp; clay</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Clay</u>		<u>20</u>	<u>25</u>	<u>30</u>
<u>Big gravel</u>		<u>75</u>	<u>160</u>	<u>90</u>
<u>Course Sand &amp; small Brown gravel</u>	<u>0</u>	<u>160</u>	<u>190</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>14</u>	<u>1 5/8</u>	<u>11</u>	<u>+1</u>
<u>6 3/8</u>		<u>SDR 21</u>	<u>11</u>	<u>190</u>

Perforations:  
 Type perforation S&W  
 Size perforation 3/16  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 130 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 190 feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 60.0 °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling Inc. Contractor  
 Address P.O. Box 599 Contractor  
Silver Springs, NV. 89429  
 Nevada contractor's license number issued by the State Contractor's Board. 1878 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1878  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_

Date started 6-1-04, 20\_\_\_\_  
 Date completed 6-2-04, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>204</u>	<u>100</u>	<u>1 Hr</u>

RECEIVED  
 04 JUN 23 AM 11:44  
 STATE ENGINEERS OFFICE