

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27602

1. OWNER LARRY + TERRI WILLIAMS ADDRESS AT WELL LOCATION 1136 Marble Ave
 MAILING ADDRESS MARBLE AVE. + PAWNEE ST. SANDY VALLEY NV 088

2. LOCATION SE 1/4 NE 1/4 Sec 26 T 24 N R 56 E CLARK County
 PERMIT NO. 200-26-601-032 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	3	3
CLAY		3	26	23
CALICHE		26	32	6
CLAY		32	56	24
CALICHE		56	60	4
CLAY		60	74	14
CALICHE	W.B	74	84	10
CLAY		84	92	8
CALICHE	W.B	92	105	13
CLAY		105	125	20
CALICHE	W.B	125	131	6
CLAY		131	137	6
CALICHE	W.B	137	140	3

DCNR/DWR
RECEIVED
MAR 07 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140 Feet
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 8 INCH BY 6 INCH
 From 140 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 FT.
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 64 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO. Contractor
 Address P.O. Box 3505 Prater NV 89041 Contractor
 Nevada contractor's license number 40020 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1573 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 2-14-2005

Date started 2-8 2005
 Date completed 2-12 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)