

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26447

1. OWNER SCOTT NABER ADDRESS AT WELL LOCATION 1650 GYPSUM AVE  
 MAILING ADDRESS GYPSUM AVE. + POLONA ST. SANDY VALLEY NV. 898

2. LOCATION NE 1/4 SW 1/4 Sec. 23 T. 24 N. R. 56 E CLARK County  
 PERMIT NO. 200-23-301-029 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	6	6
CLAY		6	32	26
CALICHE		32	37	5
CLAY		37	58	21
CALICHE		58	62	4
CLAY + GRAVEL		62	87	25
CALICHE	WB	87	92	5
CLAY + GRAVEL		92	112	20
CALICHE	WB	112	119	7
CLAY + GRAVEL		119	132	13
CALICHE	WB	132	140	8

DCNR/DWR  
 RECEIVED  
 MAR 07 2005  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.578</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/2 INCH BY 6 INCH  
 From 140 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50 FT.

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 140 feet to 50 feet

9. WATER LEVEL  
 Static water level 8.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

Date started 1-10 2005  
 Date completed 1-18 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Budget Drilling Co. Contractor  
 Address P.O. Box 3505 Pahrump NV Contractor  
89041  
 Nevada contractor's license number 40020 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Donnie Brown  
 By driller performing actual drilling on site or contractor  
 Date 2-7-2005