COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95288
Permit No.
Basin 101
NOTICE OF INTENT NO. 53798

1. OWNER Al Ingles
MAILING ADDRESS P.O. Box 2159
Fallon,NV 89407

ADDRESS AT WELL LOCATION Al Ingles
1621 Potpourri Lane
Fallon, NV

2. LOCATION se ¼ nw ¼ Sec 22 T 19 N R 28 E Churchill County

PERMIT NO. (Issued by Water Resources) 008-221-20 (Parcel No) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Brown Clay		10	19	9
Brown Sand		19	35	16
Gray Clay		35	36	1
Gray Sand		36	38	2
Brown Sand		38	45	7
Black Clay		45	50	5
Black Sand		50	55	5
Gray Clay		55	57	2
Gray Sand		57	75	18
Brown Clay		75	76	1
Brown Sand	XXX	76	85	9

RECEIVED 04 NOV 24 AM 10:51 STATE ENGINEERS OFFICE

Date started 09/30, 20 04
Date completed 09/30, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	85 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	85

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 80 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 85 feet

9. WATER LEVEL

Static water level 23 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 11/5/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9428 · FormsOnADisk.com