COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95321
Permit No.
Basin 101

NOTICE OF INTENT NO. 53794

1. OWNER Frank Woolsey
MAILING ADDRESS 2171 W Williams PMB 280
Fallon, NV 89406

ADDRESS AT WELL LOCATION Frank Woolsey
1444 Meadowlark
Fallon, NV 89406

2. LOCATION SE ¼ se ¼ Sec 21 T 19 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 008-283-13 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	8	8
Brown Clay		8	19	11
Brown Sand		19	30	11
Gray Caly		30	35	5
Gray Sand		35	41	6
Black Clay		41	45	4
Black Sand		45	55	5
Gray Clay		55	57	2
Gray Sand		57	58	1
Brown Clay		58	59	1
Brown Sand		59	63	4
Black Clay		63	65	2
Brown Gravel	XX	65	75	10

RECEIVED 04 OCT -6 PM 1:26 STATE ENGINEER'S OFFICE

Date started 09/16, 20 04
Date completed 09/16, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	75 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.82	.258	20	75

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 71 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 75 feet

9. WATER LEVEL

Static water level 20 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 10/01/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com