

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 95337  
 Permit No. \_\_\_\_\_  
 Basin 10  
 NOTICE OF INTENT NO. 53096

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER CASEY PROPERTIES ADDRESS AT WELL LOCATION 5525 CALEB  
 MAILING ADDRESS 4240 RENO HWY  
FALLON, NV 89406  
 2. LOCATION SE 1/4 NE 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 008-173-55 Subdivision Name N39 29.956 W118 52.019  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material   | Water Strata | From | To  | Thickness |
|------------|--------------|------|-----|-----------|
| TOP SOIL   |              | 0    | 1   |           |
| BROWN SAND |              | 1    | 18  | 17        |
| BROWN CLAY |              | 18   | 21  | 3         |
| BROWN SAND |              | 21   | 45  | 24        |
| BROWN CLAY |              | 45   | 50  | 5         |
| GRAY SAND  |              | 50   | 80  | 30        |
| BLACK SILT |              | 80   | 90  | 10        |
| GRAY SAND  |              | 90   | 100 | 10        |
| BROWN SAND | X            | 100  | 115 | 15        |

8. WELL CONSTRUCTION  
 Depth Drilled 115 Feet Depth Cased 115 Feet  
 HOLE DIAMETER (BIT SIZE)  

|                      | From           | To              |
|----------------------|----------------|-----------------|
| <u>10 3/4</u> Inches | <u>0</u> Feet  | <u>50</u> Feet  |
| <u>6 1/4</u> Inches  | <u>50</u> Feet | <u>115</u> Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>12.9</u>         | <u>.188</u>             | <u>+2</u>   | <u>115</u> |

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080  
 From 105 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WELSCO CORP. Contractor  
 Address P. O. BOX 888 Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 11/21/1920

Date started 10/11/1904 .19  
 Date completed 10/26/1904 .19

7. WELL TEST DATA

| TEST METHOD:   | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift |           |                               |              |
| <u>AIR LIFT</u>  | <u>25</u> |                               | <u>1 HR</u>  |

RECEIVED  
 04 DEC - 7 AM 11:35  
 STATE ENGINEERS OFFICE