

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 95344  
 Permit No. 71417  
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27407

1. OWNER ROBERT MAXEY ADDRESS AT WELL LOCATION 7142 HALEY AVE.  
 MAILING ADDRESS 2001 PLAZA DE SANTA FE LAS VEGAS, NV  
LAS VEGAS, NV 89102

2. LOCATION SE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec 22 T 19 S R 60 E CLARK County

PERMIT NO. 71417 Issued by Water Resources  
 CLARK Parcel No. 125-22-601-024 - 08B Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. DM PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Depth 456'				
PVC 6" cased (-1 foot)				
Gravel pack from 456' to 217'				
Cement 217' to surface.				
Silt		0	20	
Caliche & silty clay layers		20	35	
Clay & Rock		35	132	
Silty clay & sanstone		132	258	
White clay		258	274	
Silty clay		274	325	
Gravel		325	330	
White sandstone		330	365	
Hard rock clay		365	456	

8. WELL CONSTRUCTION

Depth Drilled 456 Feet Depth Cased 457 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 456 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>		

Perforations:  
 Type perforation Machine  
 Size perforation .032 5 rows of slots  
 From 456 feet to 256 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 217  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 456 feet to 217 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
 (CONTRACTOR)  
 Address 4015 WEST TOMPKINS AVE.  
 (CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301  
 Signed [Signature]  
 By driller performing actual drilling on site of contractor  
 Date 3/16/05

7. WELL TEST DATE

Date started 3/4, 20 05  
 Date completed 3/7, 20 05

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Air</u>	<u>60</u>	<u>?</u>	<u>1 hour</u>

RECEIVED  
 05 MAR 24 AM 9:21  
 STATE ENGINEERS OFFICE

DCNR/DWR  
 RECEIVED

MAR 21 2005

LAS VEGAS OFFICE