

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27008

1. OWNER Bill Friedman ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 8200 W. Lane Mtn. rd
Las Vegas, NV 89129 Amargosa Valley, NV 89020
 2. LOCATION NW 1/4 NW 1/4 Sec 35 T 16 N 48 E County NYE
 PERMIT NO. 19-091-13 Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & gravel		0	65	65
void	1 st	65	75	10
Limestone		75	90	15
Limestone w/ clay layers		90	180	90
void	2 nd	180	185	5
Limestone w/ clay sand layers		185	215	30
Bottom of Well			215	

8. WELL CONSTRUCTION
 Depth Drilled 215 Feet Depth Cased 215 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 2 1/2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>215</u>
<u>8</u>	<u>steel</u>	<u>.188</u>		

Surface Protective Casings:
8 steel

Perforations:
 Type perforation Machined
 Size perforation 6 R 032 screen
 From 95 feet to 115 feet
 From 135 feet to 155 feet
 From 175 feet to 195 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 215 feet

**DCNR/DWR
 RECEIVED**

MAR 17 2005

LAS VEGAS OFFICE

Date started 2/7, 2005
 Date completed 2/9, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cock Drilling Co. Contractor
 Address H.C. 70, Box 543 Contractor
Amargosa Valley, NV 89020
 Nevada contractor's license number 5376-A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2160
 Division of Water Resources, the on-site driller
 Signed Reed D. [Signature]
 By driller performing actual drilling on site or contractor
 Date 03/19/05