WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95387
Permit No.
Basin 85

NOTICE OF INTENT NO. 47965

1. OWNER Washoe County Dept of Water
MAILING ADDRESS Resources 4930 Energy Way Reno Nv 775-954-4654
ADDRESS AT WELL LOCATION Sky Ranch Park #2 8900 La Posada Sparks Nv (Spanish Springs Valley)
2. LOCATION SW ¼ SW ¼ Sec. 35 T. 21 N/S R. 20 E. Washoe County
PERMIT NO. M/O 1325 Issued by Water Resources
53409101 Parcel No.
Sky Ranch Park Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown (moist From irrigation) Clayey loam | | 0 | 3 | 3 |
| Very Black medium (#16-#18) Sandy loam - lots of organics | | 3 | 4 | 1 |
| Dark Brown very fine Sandy Clay | | 4 | 7 | 3 |
| Tan Sandy Clay | | 7 | 11 | 4 |
| Dark brown medium Sand | | 11 | 17 | 6 |
| Gravelly Clay | | 17 | 21 | 4 |
| Silty Clay | | 21 | 23 | 2 |
| Lite Tan silty fine Sand | | 23 | 25 | 2 |
| Silty Clay | | 25 | 27 | 2 |
| Brown Clayey Sand (Friable) | | 27 | 36 | 9 |
| Brown medium Sandy Clay | | 36 | 43 | 7 |
| Water Strata | 43 | | | |
| Tan, Wet, Silty Fine Sand | | 43 | 45 | 2 |

Date started 6-2-04, 19
Date completed 6-2-04, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 45' Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 6.625 | 0 | 45 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | PVC | Sch 40 | 0 | 45 |
| | | | | |

Perforations:
Type perforation Slot
Size perforation 0.020
From 40 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 To 33
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 37 feet to 45 feet

9. WATER LEVEL
Static water level 37.29 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R.N. Pennington (Contractor)
Address 333 W. Nye Lane (Contractor)
Carson City Nv 89706
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP-1857
Signed R.N. Pennington (By driller performing actual drilling on site or contractor)
Date 6-3-04

(Rev. 3-94)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627