


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
Log No. 95452
Permit No. _____
Basin 103

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53454

1. OWNER Thomas Strong ADDRESS AT WELL LOCATION 12280 GENECA
MAILING ADDRESS _____
2. LOCATION SW 1/4 NW 1/4 Sec 7 T 11 N/S R 23 E Lyon County
PERMIT NO. 15-323-01 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-ROCK		0	18	18
COBBLES/BOULDERS		18	68	50
FRAC ROCK		68	116	48
YELLOW CLAY-ROCK		116	172	56
DS-YELLOW CLAY	X	172	184	12
FRAC GRANITE		184	210	26
WHITE GRANITE		210	230	20
GRAY-GREEN ROCK	X	230	280	50

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet
HOLE DIAMETER (BIT SIZE)
From To
105/8 Inches 0 Feet 50 Feet
97/8 Inches 50 Feet 150 Feet
83/4 Inches 150 Feet 280 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>14</u>	<u>1.88</u>	<u>±1</u>	<u>20</u>
<u>65/8</u>	<u>4</u>	<u>SDR. 21</u>	<u>20</u>	<u>280</u>

Perforations:
Type perforation GRINDER CULT
Size perforation 0.45" x 5"
From _____ feet to _____ feet
From 200 feet to 280 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 36 ft Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 56 feet to 280 feet

9. WATER LEVEL
Static water level 143 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO. INC.
Address P.O. BOX 1255 Carson City, NV 89702

Date started 7 Sep 2004
Date completed 17 Sep 2004

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>18-20</u>		<u>1.5</u>

Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Blain
By driller performing actual drilling on site or contractor
Date _____

RECEIVED
04 OCT -7 AM 3:58
STATE ENGINEERS OFFICE