COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95480
Permit No.
Basin 101
NOTICE OF INTENT NO. 53784

1. OWNER Kim D. Neal
MAILING ADDRESS 970 S Crook Road
Fallon, NV 8406

ADDRESS AT WELL LOCATION Kim D. Neal
970 S Crook Road
Fallon, NV

2. LOCATION sw ¼ se ¼ Sec 33 T 19 N R 29 E Churchill County

PERMIT NO. (Issued by Water Resources) | 7-851-12 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Brown Clay		3	15	12
Brown Sand		15	23	8
Gray Clay		23	27	5
Gray Sand		27	45	18
Gray Clay		45	62	17
Gray Sand		62	79	17
Gray Clay		79	89	10
Gray Sand		89	110	21
Brown Clay		110	115	5
Brown Sand	XX	115	123	8

RECEIVED 04 NOV 24 AM 10:51 STATE ENGINEER'S OFFICE

Date started 11/01, 20 04
Date completed 11/01, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 123 Feet Depth Cased 123 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	123 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	123

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 118 feet to 123 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 123 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL

Static water level 8 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 11/5/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com