WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95482
Permit No.
Basin 089

NOTICE OF INTENT NO. 53977

1. OWNER George W. Gillemot
MAILING ADDRESS 4814 Old Hwy. 395
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 4500 Old Hwy. 395

2. LOCATION NW 1/4 SW 1/4 Sec. 03 T 16N N/S R 19E E Washoe County
PERMIT NO. 71545-T (172058 (APP)) Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray coarse sand		0	120	120
Gray coarse sand	x	120	280	160
Brown coarse sand some fine	x	280	320	40
Brown coarse sand	x	320	360	40
Brown coarse sand and rock	x	360	502	142

RECEIVED 04 NOV 9 AM 10:47 STATE ENGINEERS OFFICE

Date started 10/9/2004 , 19__
Date completed 10/13/2004 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	500-1000		3
Pump	350	180 Ft.	48 Hrs

8. WELL CONSTRUCTION
Depth Drilled 502 Feet Depth Cased 502 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17.5	Inches	0	Feet	502	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28	.250	+2	502

Perforations:
Type perforation Machine cut
Size perforation .060 x 3 Double row
From 302 feet to 502 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 502 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 10/18/2004

USE ADDITIONAL SHEETS IF NECESSARY