



Log No. 95535
Permit No. _____
Basin 102

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53584

1. OWNER Stuhlmacher ADDRESS AT WELL LOCATION 5225 WHITE OAK SILVER SPRINGS, NV
MAILING ADDRESS _____
2. LOCATION NW 1/4 NW 1/4 Sec. 1 T 17 N/S R. 24 E. LYAN County
PERMIT NO. 17-021-04 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT-CLAY		0	4	4
CLAY-GRAVEL		4	20	16
BROWN STICKY CLAY		20	55	35
LOOSE FRAC ROCK	X	55	135	70
SOLID BLACK ROCK		125	155	30
FRAC ROCK-GRAVEL	X	155	195	40

8. WELL CONSTRUCTION
Depth Drilled 195 Feet Depth Cased 195 Feet
HOLE DIAMETER (BIT SIZE)
From 11 Inches To 0 Feet 195 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.5/8</u>	<u>14</u>	<u>.188</u>	<u>7.1</u>	<u>15</u>
<u>6.5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>15</u>	<u>195</u>

Perforations:
Type perforation GRINDER CUT
Size perforation .045" x 4"
From _____ feet to _____ feet
From 135 feet to 195 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 58 FT Neat Cement
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 58 feet to 195 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO. INC.
Address P.O. Box 1255 Carson City, NV 89702

Date started 2 Nov 2004
Date completed 5 Nov 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18-30</u>		<u>2.5</u>

Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson
By driller performing actual drilling on site or contractor
Date _____

RECEIVED
04 DEC -6 PM 3:24
STATE ENGINEERS OFFICE