


REPORT NO. **A05.006**

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



LOG NO. **95609**
PERMIT NO. _____
BASIN **82**

NOTICE OF INTENT NO. **54816**

1. OWNER **Target Minerals Inc.** ADDRESS OF WELL **Oling House**
MAILING ADDRESS **14605 Seminole Trail Reno NV 89511** **Nevada**
2. WELL LOCATION **NW** 1/4 **NW** 1/4 SEC. **29** T **21** R **23** E **Washoe** COUNTY
PERMIT NO **70975** PARCEL NO **79-150-55** SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Brown Sandy Clay, & Dark Green,		0		
Purple Rock		0	17	17
Yellow Clay & Green Rock		17	30	13
Dark Blue, Green Rock Less Clay		30	38	8
Green Basalt Some Quartz		38	45	7
Hard Yellow & Green Clay		45		
Stone Green Rock		45	50	5
Hard Drk Blue Green Basalt, Quartz		50	90	40
Light Gray Blue Mixed With Basalt		90	115	25
Turquoise Rock, Basalts Drk Blue		115	125	10
Thick Reddish Brown Hard Clay		125		
& Black Basalts		125	150	25
Blue Green Basalts		150	240	90
Blue Green Rock & Volcanic Rock		240	300	60
Blue Green Basalts & Red Purple		300		
Volcanic Rock		300	340	40
Turquoise Colored Basalts		340	363	23

8. WELL CONSTRUCTION

Depth Drilled **363** Depth Cased **363**

HOLE DIAMETER (BIT SIZE)

10 Inches **0** Feet **50** Feet

8 1/2 Inches **50** Feet **363** Feet

_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+3	363

PERFORATIONS:

Type Perforation **Factory** Size Perforation **3/32 X 3**

From **323** Feet to **363** Feet

From _____ Feet to _____ Feet

From _____ Feet to _____ Feet

SURFACE SEAL: Yes No SEAL TYPE:

Seal Depth **50** Neat Cement

PLACEMENT METHOD: Pumped Concrete Grout

Poured Bentonite

GRAVEL PACKED: Yes No

From **50** Feet to **363** Feet

9. WATER LEVEL

Static Water Level **225** Feet Below Land Surface

Artesian Flow _____ GPM _____ PSI

Water Temperature **Cool** F Quality **Clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**

Address **675 Edison Way**

Reno, NV 89502

DRILLER'S LIC. NO. _____
NV. CONTRACTOR'S LIC. NO. **15291** ON SITE **2189**

Signed *Roger Mitchell*

By driller performing actual drilling on site or contractor

Dated **January 31, 2005**

Notes : UTM:

0291546

4393237 Elevation: 6000'

Date Started **1/27/05**

Date Completed **1/31/05**

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20		2Hrs.