COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 956061
Permit No.
Basin 101
NOTICE OF INTENT NO. 55124

1. OWNER Coverston Constutruction
MAILING ADDRESS P.O. Box 1016
Fallon, NV 8406

ADDRESS AT WELL LOCATION Coverston Construction
4637 Rancheria Drive
Fallon, NV 89406

2. LOCATION ~~nw~~ SE ¼ nw ¼ Sec 16 T 19 N R 28 E Churchill County

PERMIT NO. (Issued by Water Resources) | 008-121-88 (Parcel No) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Brown Clay		2	16	14
Brown Sand		16	21	5
Gray Clay		21	24	3
Brown Clay		24	33	9
Brown Sand		33	45	12
Black Sand		45	59	14
Black Clay		59	64	5
Black Sand		64	90	26
Gray Clay		90	97	7
Brown Clay		97	103	6
Brown Sand		103	109	6
Gravel		109	125	14
Brown Sand		125	135	10
Gray Sand		135	142	7
Black Clay		142	146	4
Black Sand		146	185	39
Brown Clay		185	192	7
Brown Sand	XX	192	202	10

RECEIVED 05 MAR 25 AM 10 13 STATE ENGINEER'S OFFICE

Date started 03/04, 20 05
Date completed 03/04, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. WELL CONSTRUCTION

Depth Drilled 202 Feet Depth Cased 202 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	202 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	202

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 197 feet to 202 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 202 feet

9. WATER LEVEL

Static water level 33 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753 T1
Signed
By driller performing actual drilling on site or contractor
Date 03/24/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com