WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95687
Permit No.
Basin 89

NOTICE OF INTENT NO. 53700

1. OWNER Ramsdell Ltd. Partnership
MAILING ADDRESS P.O. Box 434
Glenbrook, NV 89413

ADDRESS AT WELL LOCATION 7299 Franktown Rd.

2. LOCATION NW 1/4 SE 1/4 Sec. 22 T 16N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
055-210-20 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| On this date we abandoned the 8" x 184' well. We perforated to surface because there was no sanitary seal. We then pumped approximately 7.75 cu. yards neat cement mixed 5.2 gallons/sack from the bottom to top using tremmie pipe. We then cut the top 2' off the casing. | | | | |
| Washoe Co. Permit #040252 | | | | |

Date started 3/2/2005, 19__
Date completed 3/3/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 184 Feet Depth Cased 184 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| Inches | Feet | Feet | Feet |
| Inches | Feet | Feet | Feet |
| Inches | Feet | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 10 gauge | | +1 | 122 |
| 6 5/8 | 12.92 | .188 | 110 | 184 |

Perforations:
Type perforation Puncture
Size perforation Mills Knife
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 184
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 162 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Not Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay By driller performing actual drilling on-site or contractor
Date 2/16/2005

USE ADDITIONAL SHEETS IF NECESSARY