COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95727
Permit No.
Basin 101

NOTICE OF INTENT NO. 54857

1. OWNER Jeff L Christiansen
MAILING ADDRESS 235 S Maine Street
Fallon, NV 89406

ADDRESS AT WELL LOCATION Jeff L Christiansen
4570 Reno Hwy
Fallon, NV 89406

2. LOCATION ne ¼ nw ¼ Sec 28 T 19n N R 28 E Churchill County

PERMIT NO. 67057 (Issued by Water Resources) | 008-472-53 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Brown Clay		5	18	13
Brown Sand		18	23	5
Gray Clay		23	29	5
Gray Sand		29	46	13
Black Clay		46	52	6
Black Sand		52	70	18
Gray Clay		70	83	13
Gray Sand		83	90	7
Brown Clay		90	93	3
Brown Sand		93	98	5
Gray Clay		98	105	7
Gray Clay		105	126	21
Black Clay		126	140	14
Black Sand		140	153	13
Brown Clay		153	155	2
Brown Sand	XX	155	162	7

RECEIVED
JAN 11 2004
STATE ENGINEER'S OFFICE

Date started 12/20, 20 04
Date completed 12/21, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 162 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	162 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6	3.92	.258	20	162

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 157 feet to 162 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 162 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed
By driller performing actual drilling on site or contractor
Date 01/11/2004

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com