COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95728
Permit No.
Basin 101
NOTICE OF INTENT NO. 54865

1. OWNER Jeff L Christiansen
MAILING ADDRESS 235 S Maine Street
Fallon, NV 89406

ADDRESS AT WELL LOCATION Jeff L Christiansen
899 Lovelock Hwy
Fallon, NV 89406

2. LOCATION ne ¼ nw ¼ Sec 30 T 19 N R 29 E Churchill County

PERMIT NO. 67060 (Issued by Water Resources) | 007-691-11 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Brown Clay		2	8	5
Brown Sand		8	24	16
Black Clay		24	32	4
Black Sand		32	55	23
Black Clay		55	63	8
Black Sand		63	86	23
Brown Sand		86	93	7
Brown Clay		93	115	22
Gray Clay		115	138	23
Green Clay		138	144	6
Gray Sand		144	155	11
Gray Clay		155	158	3
Gray Sand		158	173	15
Gray Clay		173	195	22
Brown Clay		195	196	1
Brown Sand	XX	196	203	7

RECEIVED 05 JAN 13 PM 1:30 STATE ENGINEER'S OFFICE

Date started 12/23, 20 04
Date completed 12/27, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 203 Feet Depth Cased 203 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	203 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6	3.92	.258	20	203

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 197 feet to 203 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 203 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed
By driller performing actual drilling on site or contractor
Date 01/11/2004

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com