

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54728

1. OWNER Kim McCreary ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
SF SE 9 1/4 SW 1/4 Sec. 78 T. 20 N/S R. 24 E  Lyon Co County  
 2. LOCATION  
 PERMIT NO. N/A Issued by Water Resources | 021-114-20 Parcel No. | 021-051-46 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Clay &amp; Boulders</u>		<u>0</u>	<u>150</u>	
<u>Clay</u>		<u>150</u>	<u>240</u>	
<u>Black Rock clay</u>		<u>240</u>	<u>300</u>	
<u>Black Red Rock</u>	<u>N</u>	<u>300</u>	<u>363</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 363 Feet Depth Cased 363 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 158 Feet  
6 7/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
6 7/8 Inches 158 Feet 363 Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>1.88</u>	<u>71</u>	<u>158</u>
<u>5</u>		<u>SDR 21</u>	<u>120</u>	<u>363</u>

Perforations:  
 Type perforation jetting  
 Size perforation 5/16  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 280 feet to 363 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 158 feet

Date started 11-15-04, 20\_\_\_\_  
 Date completed 11-20-04, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>9</u>	<u>360</u>	<u>1 Hr</u>

9. WATER LEVEL  
 Static water level 1.76 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 100 °F Quality Clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lance Drilling Contractor  
 Address Bx 599 Silver Springs Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 31841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-5-05



1/10

