WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95854
Permit No.
Basin 044

NOTICE OF INTENT NO. 34275

1. OWNER WILLIAM KROHN
MAILING ADDRESS HC 187-1
ELKO, NV 89801

ADDRESS AT WELL LOCATION 5870 COAL MINE CANYON ROAD

2. LOCATION SE 1/4 NW 1/4 Sec. 6 T 35N N/S R 57E E ELKO County
PERMIT NO. 70887 (Issued by Water Resources) Parcel No. 030-035-019 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TAN COLORED CLAY		0	7	7
FINE SAND & GRAVEL		7	18	11
CEMENTED GRAVEL		18	26	8
CALICHI CLAY		26	168	142
SANDY GRAVEL	X	168	170	2
CALICHI CLAY		170	180	10
SANDY GRAVEL	X	180	181	1
CALICHI CLAY		181	200	19

RECEIVED
05 JAN 31 AM 11:32
STATE ENGINEERS OFFICE

Date started 1/5/2005 , 19__
Date completed 1/17/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	200		7.5

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	18
6	SDR-17		18	200

Perforations:
Type perforation SCREEN
Size perforation .050
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Benonite 19-60
Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 1/18/2005

USE ADDITIONAL SHEETS IF NECESSARY