COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95916
Permit No.
Basin 107

NOTICE OF INTENT NO. 53554

1. OWNER ROB STINNETTE CONSTRUCTION
MAILING ADDRESS P.O. BOX 11
WELLINGTON, NV 89444

ADDRESS AT WELL LOCATION # 60 YELLOW ~~JACKET~~ Sage
SMITH VALLEY, NV 89444

2. LOCATION ~~SW~~ NW ¼ ~~SW~~ SE ¼ Sec 12 T 11 N R 23 E LYON County

PERMIT NO. (Issued by Water Resources) 009-132-05 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEB		0	3	3
BROWN SANDS AND CLAY		3	56	53
BROWN CLAY		56	84	28
GRAY SILTY SANDS	XX	84	180	96
GRAY CLAY				

RECEIVED 05 MAR 22 AM 11:43 STATE ENGINEERS OFFICE

Date started 3/7, 20 05
Date completed 3/8, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	30	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1303	.188	+2	20
6 5/8 sdr21	4.06	.216	20	180

Perforations:
Type perforation SAW CUT
Size perforation 3X3/32
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Michael L Hack / Rick Cave
By driller performing actual drilling on site or contractor
Date 1/20/05

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429