


COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 95920
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53557

1. OWNER **WYMAN CONSTRUCTION**
 MAILING ADDRESS _____

ADDRESS AT WELL LOCATION **196 TAYLOR CREEK RD**
GARDNERVILLE, NV 89410

GARDNERVILLE, NV 89410

2. LOCATION SW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec 9 T 12 N R 19 E **DOUGLAS** County

PERMIT NO. NE NE **1219-04-001-017**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
COURSE DG SANDS		0	6	6
DARK BROWN SANDS				
RUSTY BROWN DG SANDS AND CLAY		6	47	41
BROWN CLAY		47	110	63
SILTY GRAY SANDS		110	157	47
GRAY CLAY		157	160	3
FRACTURED DG SANDS AND COBBLES		160	180	20
COURSE DG SANDS		180	213	33
BROWN CLAY		213	220	7
FRACTURED GRANITE	XXX	220	240	20
LOOSE SANDS				

8. WELL CONSTRUCTION				
Depth Drilled	240 Feet	Depth Cased	240 Feet	
HOLE DIAMETER (BIT SIZE)				
	From		To	
	10 3/4 Inches	0 Feet	240 Feet	
	Inches	Feet	Feet	
	Inches	Feet	Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	240
Perforations:				
Type perforation	SAW CUT			
Size perforation	3 X 3/32			
From	200 feet to	240 feet		
From	feet to	feet		
From	feet to	feet		
From	feet to	feet		
From	feet to	feet		
Surface Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Seal Type:				
Depth of Seal	100	<input checked="" type="checkbox"/> Neat Cement		
Placement Method: <input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Cement Grout				
<input type="checkbox"/> Poured <input type="checkbox"/> Concrete Grout				
Gravel Packed: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
From	100 feet to	240 feet		
9. WATER LEVEL				
Static water level	60 feet below land surface			
Artesian flow	G.P.M. 25+ P.S.I.			
Water temperature	COLD °F Quality GOOD			
10. DRILLER'S CERTIFICATION				
This well was drilled under my supervision and the report is true to the best of my knowledge.				
Name CAPITAL CITY WELL DRILLING				
(CONTRACTOR)				
Address 20 KIT KAT DRIVE				
(CONTRACTOR)				
CARSON CITY, NV 894706				
Nevada contractor's license number issued by the State Contractor's Board 0055548				
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157				
Signed <i>Rick Crane</i>				
By driller performing actual drilling on site or contractor				
Date 1/21/05				

Date started **3/13, 20 05**
 Date completed **3/14, 20 05**

7. WELL TEST DATE			
TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
	Draw Down (Feet Below Static)		Time (Hours)
	25+	100	3 HRS

RECEIVED
 03 MAR 22 AM 11:43
 STATE ENGINEERS OFFICE