



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55005

1. OWNER BARRICK / Ruby Hill ADDRESS AT WELL LOCATION 2 1/2 miles west on Hwy 50/1 mile south off 60 at Ruby Hill mine  
 MAILING ADDRESS PO BOX 676 Eureka NV 89316  
 2. LOCATION SW 1/4 NE 1/4 Sec. 9 T. 19 N/S R. 53 E. EUREKA County  
 PERMIT NO. 53005 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. RIB-P22 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel		0	190	190
gray limestone		190	225	35
1 super sack of 1/4 gravel + 26 bag 50 lb of washed 1/4 gravel		25	225	200
12 bags of 94 lb cement poured		25	0	25

8. WELL CONSTRUCTION  
 Depth Drilled 225 Feet Depth Cased 225 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 3/4 Inches To 20 Feet  
 From 6" Inches To 225 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.156</u>	<u>0</u>	<u>20</u>
<u>2"</u>		<u>.156</u>	<u>20</u>	<u>225</u>

Perforations:  
 Type perforation slotted  
 Size perforation 1/8  
 From 25 feet to 225 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 25  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 25 feet to 225 feet

9. WATER LEVEL  
 Static water level did not contact feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eklund Drilling Co Contractor  
 Address 605 Union Pacific Way Contractor  
EKO NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0230823  
 Nevada driller's license number issued by the Division of Water Resources M 2262  
 Signed Frank Eklund  
 By driller performing actual drilling on site or contractor  
 Date 02/01/05

Date started Feb 06, 2005  
 Date completed Feb 07, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>No water contacted</u>		<u>0.2</u>	<u>12:00</u>