WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.[illegible]

OFFICE USE ONLY
Log No. 95932
Permit No.
Basin 131

NOTICE OF INTENT NO. 35009

1. OWNER Newmont Mining Co
MAILING ADDRESS P.O. Box 388
Valmy, NV 89438

ADDRESS AT WELL LOCATION 15 miles So of Battle Mtn at the Phoenix Project

2. LOCATION NE ¼ NW ¼ Sec. 28 T. 31 N/S R. 43 E. Lander County

PERMIT NO. M/0467A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Depth to Water at time of Abandonment			899.8	
Material Used				
(12) 94# Sacks of Portland Cement				
Pumped down approx 90 gal. of neat Cement				
Avg. wt. was 15.6/gal				

RECEIVED 05 MAR -8 AM 10:47 STATE ENGINEERS OFFICE

Date started 2-16, 2005
Date completed 2-16, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.5	—	Sch 80	0	1025

Perforations:
Type perforation Unknown
Size perforation Unknown
From ____ feet to ____ feet
From 787 feet to 964 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 899.8 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKlund Drilling Co (Contractor)
Address P.O. Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1769
Signed Warren Hartley (By driller performing actual drilling on site of contractor)
Date 3-2-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627