Corrected

COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95946
Permit No.
Basin 101

NOTICE OF INTENT NO. 52898

1. OWNER Berney Realty
MAILING ADDRESS 290 W Williams Ave
Fallon,NV 89406

ADDRESS AT WELL LOCATION Berney Realty
2895 Peachtree Rd
Fallon, NV 89406

2. LOCATION nw ¼ sw ¼ Sec 6 T 18 N R 29 E Churchill County

PERMIT NO. (Issued by Water Resources) | 006-741-46 (Parcel No) | (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Brown Clay		4	6	2
Brown Grael		6	18	12
Gra Clay		18	30	12
Black Sand		30	57	27
Black Clay		57	60	3
Black Sand		60	68	8
Black Clay		68	85	17
Black Clay		85	90	5
Black Sand/Gravel		90	98	8
Gray Clay		98	101	3
Brown Gravel	XX	101	108	7

RECEIVED 05 FEB 23 AM 11:41 STATE ENGINEERS OFFICE

Date started 05/20, 20 04
Date completed 05/20, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 108 Feet Depth Cased 108 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	108 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6	3.92	.258	20	108

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 103 feet to 108 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 108 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 06/01/2004 Corrected 2/17/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com